

403 Busseron Street
P. O. Box 749
Vincennes, IN 47591

VINCENNES WATER UTILITIES
2023 Water Quality Report
PWS #5242014

Phone: 812-882-7877
FAX: 812-882-9206
Emergency: 812-882-6620

www.vinutilities.com

OFFICE HOURS: Monday through Friday 7:30 a.m. to 4:00 p.m.

Is our water safe?

This brochure is a snapshot of the quality of the drinking water we provided last year. Included as part of this report are details about the source of the water you drink, what it contains, and how it compares to Environmental Protection Agency (EPA) and Indiana standards. We are committed to providing you this information about the quality of the water you drink.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplant, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.

What is the source of our water?

The source of water for the City of Vincennes is from seven wells situated one-half mile southwest of the city and adjacent to the Wabash River. Treatment consists of the addition of chlorine, fluoride, and phosphate for sequestering iron and manganese. The first wells were installed around 1950 when the waterworks moved from Scott Street to its present location on South River Road.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water may include:

- Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife
- Inorganic Contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming
- Pesticides and Herbicides, which may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses
- Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems
- Radioactive Contaminants, which can be naturally-occurring or the result of oil and gas production and mining activities

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Availability of a Source Water Assessment (SWA)

A Source Water Assessment (SWA) has been prepared for our system. According to this assessment, our system has been categorized with a high (detection) susceptibility risk. More information of this assessment can be obtained by contacting our office at 812-882-7877.

Our Watershed Protection Efforts

Our water system is working with the community to increase awareness of better waste disposal practices to further protect the sources of our drinking water. We are also working with other agencies and local watershed groups to educate the community on ways to keep our water safe.

Public Involvement Opportunities

The Vincennes Water Utilities General Manager is L. Kirk Bouchie. Vincennes Water Utilities activities are governed by the Vincennes Utilities Services Board which meets on the second Wednesday of each month at 4:00 p.m. in the Vincennes Drinking Water Meeting Room at 1134 River Road.

Please Share This Information

Large water volume customers (like apartment complexes, hospitals, schools, and/or industries) are encouraged to post extra copies of this report in conspicuous locations or to distribute them to your tenants, residents, patients, students, and/or employees. This "good faith" effort will allow non-billed customers to learn more about the quality of the water that they consume.

Water Quality Data

The table below lists all the contaminants detected during the calendar year. The presence of these contaminants in the water does not necessarily indicate the water poses a health risk. Unless otherwise indicated, the data presented in this table is from testing done between January 1 and December 31, 2022. The Indiana Department of Environmental Management (IDEM) requires us to monitor for certain contaminants at a frequency less than once per year because the concentrations of these contaminants are not expected to vary significantly from one year to another. Some of the data, though representative of the water quality, may be more than one year old.

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

| Lead and Copper | Date Sampled | MCLG | Action Level (AL) | 90th Percentile | # Sites Over AL | Units | Violation (Yes or No) | Likely Source of Contamination |
|-----------------|--------------|------|-------------------|-----------------|-----------------|-------|-----------------------|---|
| Copper | 06/08/2020 | 1.3 | 1.3 | 0.67 | 0 | ppm | NO | Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems. |

Water Quality Test Results

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na: not applicable.

mrem: millirems per year (a measure of radiation absorbed by the body)

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

| Disinfectants and Disinfection By-Products | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation (Yes or No) | Likely Source of Contamination |
|--|-----------------|------------------------|--------------------------|-----------------------|----------|-------|-----------------------|--|
| Chlorine | 2022 | 1 | 1 - 1 | MRDLG = 4 | MRDL = 4 | ppm | NO | Water additive used to control microbes. |
| Haloacetic Acids (HAA5) | 2022 | 4 | 0 - 9.4 | No goal for the total | 60 | ppb | NO | By-product of drinking water disinfection. |
| Total Trihalomethanes (TTHM) | 2022 | 22 | 1.27 - 117.5 | No goal for the total | 80 | ppb | NO | By-product of drinking water disinfection. |
| Inorganic Contaminants | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation (Yes or No) | Likely Source of Contamination |
| Barium | 05/26/2020 | 0.051 | 0.051 - 0.051 | 2 | 2 | ppm | NO | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Chromium | 05/26/2020 | 1.6 | 1.6 - 1.6 | 100 | 100 | ppb | NO | Discharge from steel and pulp mills; Erosion of natural deposits. |
| Fluoride | 05/26/2020 | 0.6 | 0.6 - 0.6 | 4 | 4.0 | ppm | NO | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories. |
| Nitrate [measured as Nitrogen] | 2022 | 3 | 2.6 - 2.6 | 10 | 10 | ppm | NO | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Radioactive Contaminants | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation (Yes or No) | Likely Source of Contamination |
| Gross alpha excluding radon and uranium | 01/18/2018 | 2 | 2 - 2 | 0 | 15 | pCi/L | NO | Erosion of natural deposits. |